TEST RESULTS OF STEEL

Lab ID	:	**CP-2017-06-16-01** **Date: 27-09-2018**
Customer	:	Assistant Executive Engineer, Shettyhalli Sub Division, BBMP, Bangalore.
Address	:	Shettyhalli Sub Division, BBMP, Bangalore.
Project Name	:	Construction of RCC Drains & CC Roads at Ayyappa Layout & Mathushree Layout in ward no.13 Shettyhalli Sub Division.
Agency	:	Technical Manager (west), KRIDL, Project Implementation Unit, No.280, 59th cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagara, Bangalore-560010
Customer's Reference	:	BBMP/EE/DD/WO/103/2017-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	25-09-2018
Sample ID No	:	2017-06-16-01-01
Sample Type	:	JSW
Reference to BIS codes	:	IS 1786-2008, IS:1608-2005(RA 2011), IS 1599-2012.
Date of test:	:	26-09-2018

Sl.No	Identification of sample	Grade of the sample	Diameter of the steel bar	Weight of the sample	Yield stress	Tensile strength	Elongation	Bend test	Rebend test
			(mm)	(kg/m)	(N/mm2)	(N/mm2)	(%)		
1	JSW	Fe500	8	0.392	553	679	20.0%	Satisfactory	Satisfactory
2	JSW	Fe500	10	0.612	578	690	19.0%	Satisfactory	Satisfactory

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಶೆಟ್ಟಿಹಳ್ಳಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ವಲಯ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
ಎಸ್.ಎಂ. ಬಿ.ಬಿ. ಪ್ರಜೋತ್ಪನ್ನಗಳು

Note:
The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Scanned by CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

TEST REPORT OF PRECAST COVER SLAB

Lab ID	:	**CP-2017-06-16-01** **Date: 29-09-2018**
Customer	:	Assistant Executive Engineer, Shettyhalli Sub Division, BBMP, Bangalore.
Address	:	Shettyhalli Sub Division, BBMP, Bangalore.
Project Name	:	Construction of RCC Drains & CC Roads at Ayyappa Layout & Mathushree Layout in ward no.13 Shettyhalli Sub Division.
Agency	:	Technical Manager (west), KRIDL, Project Implementation Unit, No.280, 59th cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagara, Bangalore-560010
Customer's Reference	:	BBMP/EE/DD/WO/103/2017-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	25-09-2018
Sample ID No	:	2017-06-16-01-02
Sample Type /Size	:	Precast Cover Slab
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete
Date of test	:	25/09/2018

Sl. No.	Identification Mark	Diameter of the core	Height of the core	Weight of the core	Area	Failure Load	Core Compressive strength	Corrected Cylinder Compressive strength	Equivalent Cube Compressive strength
		(mm)	(mm)	(mm)	(Sq.mm)	(KN)	(N/mm^2)	(N/mm^2)	(N/mm^2)
1	Cover Slab-1	75.48	100.48	1.516	4474	90.9	20.3	18.9	23.6
2	Cover Slab-2	75.45	100.52	1.542	4470	92.3	20.6	19.2	24.0
3	Cover Slab-3	75.54	100.51	1.538	4481	94.5	21.1	19.6	24.5

AE
ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಶೆಟ್ಟಿಹಳ್ಳಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ವಲಯ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
ಎಸ್.ಎಂ. ರಸ್ತೆ, ರವೀಂದ್ರನಗರ, ಬೆಂಗಳೂರು

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Scanned by CamScanner

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 08/10/2018

Lab ID	:	CP-2017-06-26-09
Customer	:	Assistant Executive Engineer, Shettyhalli Sub Division, BBMP, Bangalore.
Address	:	Shettyhalli Sub Division, BBMP, Bangalore.
Project Name	:	Construction of RCC Drains & CC Roads at Ayyappa Layout & Mathushree Layout in ward no.13 Shettyhalli Sub Division.
Agency	:	Technical Manager (west), KRIDL, Project Implementation Unit, No.280, 59th cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagara, Bangalore-560010
Customer's Reference	:	BBMP/EE/DD/WO/103/2017-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	03-10-2018
Sample ID No	:	2017-06-26-09-01
Customer ID	:	PCC
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M20 / 7 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	08/10/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	PCC	M20	01/10/2018	08/10/2018	150.22 X 150.24 X 150.27	22569	8.345	390.4	17.3	17.3
2	PCC	M20	01/10/2018	08/10/2018	150.28 X 150.29 X 150.30	22586	8.367	393.0	17.4	
3	PCC	M20	01/10/2018	08/10/2018	150.31 X 150.20 X 150.25	22577	8.323	386.1	17.1	

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಶೆಟ್ಟಿಹಳ್ಳಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ವಲಯ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
ಎಸ್.ಎಸ್.ಕೆ. ಸ್ಕೀಮ್, ರವೀಂದ್ರನಗರ, ಬೆಂಗಳೂರು

Note:
The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

FOR CIVIL Pro.

CIVIL Pro BANGALORE Sig..... Date.....

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****

Scanned by CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC- 5548

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : CP-2017-06-26-09 **Date: 29/10/2018**

Customer : Assistant Executive Engineer, Shettyhalli Sub Division, BBMP, Bangalore.

Address : Shettyhalli Sub Division, BBMP, Bangalore.

Project Name : Construction of RCC Drains & CC Roads at Ayyappa Layout & Mathushree Layout in ward no.13 Shettyhalli Sub Division.

Agency : Technical Manager (west), KRIDL, Project Implementation Unit, No.280, 59th cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagara, Bangalore-560010

Customer's Reference : BBMP/EE/DD/WO/103/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 03-10-2018

Sample ID No : 2017-06-26-09-02

Customer ID : PCC

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 29/10/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	PCC	M20	01/10/2018	29/10/2018	150.21 X 150.24 X 150.27	22568	8.324	521.3	23.1	23.4
2	PCC	M20	01/10/2018	29/10/2018	150.26 X 150.29 X 150.24	22583	8.354	535.2	23.7	
3	PCC	M20	01/10/2018	29/10/2018	150.28 X 150.20 X 150.25	22572	8.378	525.9	23.3	

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಶೆಟ್ಟಿಹಳ್ಳಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ವಲಯ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
ಎಸ್. ಎಂ. ರಸ್ತೆ, ರವೀಂದ್ರನಗರ, ಬೆಂಗಳೂರು

Note:
The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro BANGALORE Sig..... Date.....

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Scanned by CamScanner

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 10/10/2018

Lab ID	:	CP-2017-06-26-09
Customer	:	Assistant Executive Engineer, Shettyhalli Sub Division, BBMP, Bangalore.
Address	:	Shettyhalli Sub Division, BBMP, Bangalore.
Project Name	:	Construction of RCC Drains & CC Roads at Ayyappa Layout & Mathushree Layout in ward no.13 Shettyhalli Sub Division.
Agency	:	Technical Manager (west), KRIDL, Project Implementation Unit, No.280, 59th cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagara, Bangalore-560010
Customer's Reference	:	BBMP/EE/DD/WO/103/2017-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	05-10-2018
Sample ID No	:	2017-06-26-09-03
Customer ID	:	PCC
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M20 / 7 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	10/10/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	PCC	M20	03/10/2018	10/10/2018	150.21 X 150.24 X 150.27	22568	8.332	408.5	18.1	18.3
2	PCC	M20	03/10/2018	10/10/2018	150.28 X 150.29 X 150.22	22586	8.355	417.8	18.5	
3	PCC	M20	03/10/2018	10/10/2018	150.28 X 150.20 X 150.25	22572	8.343	410.8	18.2	

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಶೆಟ್ಟಿಹಳ್ಳಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ವಲಯ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
ಎಸ್.ಎಫ್.ಸಿ. ಸೆಕ್ಟರ್, ರವೀಂದ್ರನಗರ, ಬೆಂಗಳೂರು

Note:
The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

Scanned by CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC- 5548

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 31/10/2018

Lab ID	:	CP-2017-06-26-09
Customer	:	Assistant Executive Engineer, Shettyhalli Sub Division, BBMP, Bangalore.
Address	:	Shettyhalli Sub Division, BBMP, Bangalore.
Project Name	:	Construction of RCC Drains & CC Roads at Ayyappa Layout & Mathushree Layout in ward no.13 Shettyhalli Sub Division.
Agency	:	Technical Manager (west), KRIDL, Project Implementation Unit, No.280, 59th cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagara, Bangalore-560010
Customer's Reference	:	BBMP/EE/DD/WO/103/2017-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	05-10-2018
Sample ID No	:	2017-06-26-09-04
Customer ID	:	PCC
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M20 / 28 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	31/10/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	PCC	M20	03/10/2018	31/10/2018	150.24 X 150.27 X 150.29	22577	8.333	512.5	22.7	23.0
2	PCC	M20	03/10/2018	31/10/2018	150.28 X 150.22 X 150.24	22575	8.376	517.0	22.9	
3	PCC	M20	03/10/2018	31/10/2018	150.32 X 150.25 X 150.31	22586	8.382	528.5	23.4	

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಶೆಟ್ಟಿಹಳ್ಳಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ವಲಯ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Note:
The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO Sig..... Date..... BANGALORE

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Scanned by CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC- 5548

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID	:	**CP-2017-07-01-04** **Date: 19/10/2018**
Customer	:	Assistant Executive Engineer, Shettyhalli Sub Division, BBMP, Bangalore.
Address	:	Shettyhalli Sub Division, BBMP, Bangalore.
Project Name	:	Construction of RCC Drains & CC Roads at Ayyappa Layout & Mathushree Layout in ward no.13 Shettyhalli Sub Division.
Agency	:	Technical Manager (west), KRIDL, Project Implementation Unit, No.280, 59th cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagara, Bangalore-560010
Customer's Reference	:	BBMP/EE/DD/WO/103/2017-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	15-10-2018
Sample ID No	:	2017-07-01-04-01
Customer ID	:	Cement Concrete Pavement
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M30 / 7 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 19/10/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Cement Concrete Pavement	M30	12/10/2018	19/10/2018	150.33 X 150.30 X 150.27	22595	8.402	553.6	24.5	24.2
2	Cement Concrete Pavement	M30	12/10/2018	19/10/2018	150.31 X 150.29 X 150.30	22590	8.413	546.7	24.2	
3	Cement Concrete Pavement	M30	12/10/2018	19/10/2018	150.35 X 150.20 X 150.27	22583	8.378	537.5	23.8	

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಶೆಟ್ಟಿಹಳ್ಳಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ

Note:
- The results pertain to the samples received and tested.
- All information furnished by Customer/Representative
- Any correction in the report will make this report invalid
- This report without prior written approval should not be reproduced or published in full or part.
- Samples will be disposed after 90 days from the date of issue of test certificate

FOR CIVIL Pro.

CIVIL PRO BANGALORE Sig..... Date.....

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Scanned by CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC- 5548

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 09/11/2018

Lab ID	:	CP-2017-07-01-04
Customer	:	Assistant Executive Engineer, Shettyhalli Sub Division, BBMP, Bangalore.
Address	:	Shettyhalli Sub Division, BBMP, Bangalore.
Project Name	:	Construction of RCC Drains & CC Roads at Ayyappa Layout & Mathushree Layout in ward no.13 Shettyhalli Sub Division.
Agency	:	Technical Manager (west), KRIDL, Project Implementation Unit, No.280, 59th cross, 17th 'C' Main Road, 3rd 'Y' Block, Rajajinagara, Bangalore-560010
Customer's Reference	:	BBMP/EE/DD/WO/103/2017-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	15-10-2018
Sample ID No	:	2017-07-01-04-02
Customer ID	:	Cement Concrete Pavement
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M30 / 28 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	09/11/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Cement Concrete Pavement	M30	12/10/2018	09/11/2018	150.26 X 150.28 X 150.27	22581	8.366	724.9	32.1	31.9
2	Cement Concrete Pavement	M30	12/10/2018	09/11/2018	150.28 X 150.29 X 150.30	22586	8.380	718.2	31.8	
3	Cement Concrete Pavement	M30	12/10/2018	09/11/2018	150.30 X 150.20 X 150.27	22575	8.367	720.1	31.9	

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಶೆಟ್ಟಿಹಳ್ಳಿ ಉಪವಿಭಾಗ, ದಾಸರಹಳ್ಳಿ ವಲಯ
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
ಎಸ್. ಟಿ. ಸಂಖ್ಯೆ: [illegible]

Note:
The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Scanned by CamScanner